

**PROFORMA REGARDING SAFE DRINDING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 1872

Date: 02/05/2025

It is certified that an inspection team headed by Deputy Cmo G.B. Nagar. Raj International Jr High School, Haibatpur, G.B Nagar on dated 01-05-2025 and found that the Raj International Jr High School, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:-

Name:-

Dr Narendra Kumar

Designation:-

Chief Medical Officer

उप मुख्य चिकित्सा अधिकारी
गौतमबुद्धनगर

शिवराज शर्मा
प्रबन्धक

To

The Principal,
Raj International Jr High School,
Haibatpur,
Gautam Budh Nagar.

राज इंटरनेशनल जू0 हाई स्कूल
हैबतपुर (गौतम बुद्ध नगर)





Analyzing for an Assured
Future

NOIDA TESTING LABORATORIES

GSTIN : 09AAIEN9004D1ZD

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)
MoEF & CC (Ministry of Environment, Forest & Climate Change) UPPCB Recognized Laboratory
+91-9313611642, 8510081921, 7503031145, 8527870572, 7503031146, 9999794369

TEST CERTIFICATE

Issued To: M/s Raj International JR High School.

Address: Haibatpur, Gautambudh Nagar

Report Code : W-290325-02
ULR No. : TC681425000002852F
Test Report of : Water
Discipline : Chemical & Biological
Service Request No : NTL/SRF/03/25-02
Service Request Date : 28/03/2025
Report Issue Date : 03/04/2025

SAMPLING & ANALYSIS DATA

Sample Description : Drinking Water
Sample Given by : NTL Representative
Sample Drawn On : 29/03/2025
Sample Received On : 29/03/2025
Sample Quantity : 2.0 lit. + 500 ml.
Sample packing Details : In Sealed Plastic Bottle & Glass Bottle
Analysis Duration : 29/03/2025 to 03/04/2025
Required Test Standard : IS:10500-2012/RA 2023

MICROBIOLOGICAL REQUIREMENT RESULT

S.No.	Parameter	Test Method	Results	Requirements as per IS-10500:2012/RA 2023
1.	<i>Escherichia coli</i>	IS-15185	Absent	Absent/100ml
2.	<i>Coliform Bacteria</i>	IS-15185	Absent	Absent/100ml

ORGANOLEPTIC & PHYSICAL PARAMETER

S.No.	Parameter	Test Method	Result	Unit	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	Colour	IS-3025(P-04)	<1.00	Hazen Unit	5	15
2.	Odour	IS-3025(P-05)	Agreeable	-	Agreeable	Agreeable
3.	Taste	IS-3025(P-07 & 08)	Agreeable	-	Agreeable	-
4.	Turbidity	IS-3025(P-10)	<1.00	NTU	1	5
5.	pH value	IS-3025(P-11)	7.35	-	6.5 - 8.5	-
6.	Total dissolve solid (TDS)	IS-3025(P-16)	132.0	mg/l	500	2000



श्रीकाम भोसले
प्रबन्धक
राज इंटरनेशनल जू हाई स्कूल
हैबतपुर (गौतम बुद्ध नगर)

RAJ INTESTING LABORATORIES

(An ISO : 9001 : 2015, ISO 45001 : 2018 (OH&S) Certified & NABL Accredited Laboratory)
MoEF & CC (Ministry of Environment, Forest & Climate Change), UPPCB Recognized Laboratory
+91-9313611642, 8510081971, 7503031146, 7503031146, 9999791369

TEST CERTIFICATE

GENERAL PARAMETERS CONCERNING SUBSTANCES UNDESIRABLE IN EXCESSIVE AMOUNTS

S.No.	Parameter	Test method	Result	Unit	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	Aluminium (as Al)	IS: 3025 (P- 65)	<0.01	mg/l	0.03	0.2
2.	Total Ammonia	IS: 3025 (P- 34)	<0.10	mg/l	0.5	No Relaxation
3.	Barium (as Ba)	Annex K of IS-13428	<0.10	mg/l	0.7	No Relaxation
4.	Boron (as B)	IS: 3025 (P- 65)	<0.10	mg/l	0.5	2.4
5.	Calcium (as Ca)	IS: 3025 (P- 65)	7.15	mg/l	75	200
6.	Chloramines (as Cl ₂)	IS: 3025 (P- 40)	BDL	mg/l	4.0	No Relaxation
7.	Chloride (as Cl)	IS: 3025 (P- 26)	22.5	mg/l	250	1000
8.	Copper (as Cu)	IS: 3025 (P- 32)	BDL	mg/l	0.05	1.5
9.	Fluoride (as F)	IS: 3025 (P-65)	<0.1	mg/l	1.0	1.5
10.	Iron (as Fe)	IS: 3025(P-65)	<0.05	mg/l	1.0	No Relaxation
11.	Magnesium (as mg)	IS: 3025 (P-46)	2.58	mg/l	30	100
12.	Manganese (as Mn)	IS: 3025 (P-65)	BDL	mg/l	0.1	0.3
13.	Nitrate (as NO ₃)	IS: 3025 (P- 34)	1.02	mg/l	45	No Relaxation
14.	Selenium (as Se)	IS: 3025 (P- 65)	BDL	mg/l	0.01	No Relaxation
15.	Silver (as Ag)	IS: 3025 (P- 65)	BDL	mg/l	0.1	No Relaxation
16.	Sulphate (as SO ₄)	IS: 3025 (P- 24)	2.35	mg/l	200	400
17.	Sulphide (as H ₂ S)	IS-3025 (P-29)	BDL	mg/l	0.05	No Relaxation
18.	Alkalinity (as Ca CO ₃)	IS: 3025 (P- 23)	28.0	mg/l	200	600
19.	Total Hardness (as CaCO ₃)	IS: 3025 (P- 21)	24.0	mg/l	200	600
20.	Zinc (as Zn)	IS: 3025 (P- 65)	BDL	mg/l	5.0	15

Parameters Concerning Toxic Substances:

S.No.	Parameter	Test method	Result	Unit	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	Cadmium (as Cd)	IS-3025(P-65)	<0.001	mg/l	0.003	No Relaxation
2.	Cyanide (as CN)	IS-3025(P-27)	<0.01	mg/l	0.05	No Relaxation
3.	Lead (as Pb)	IS-3025(P-65)	<0.01	mg/l	0.01	No Relaxation
4.	Mercury (as Hg)	IS-3025(P-65)	<0.001	mg/l	0.001	No Relaxation

BDL: Below Detection limit.

Remarks-(I) Based on above tested parameter water sample meet as per IS-10500:2012 in desirable limit, Water is fit for Food/ Drinking purpose.

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the laboratory.
- The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

CHECKED BY

प्रबन्धक
राज इंटरनेशनल जू हाई स्कूल
हैबतपुर (गौतम बुद्ध नगर)

AUTHORIZED SIGNATORY



GT-20, Sector-117, Gautam Budh Nagar - 201301 (U.P.)

HARIDWAR DEHRADUN